



**Third JASTIP Symposium**  
**ASEAN-Japan STI Collaboration for SDGs**  
**February 5, 2017, Bangkok, Thailand**

# Optimal Design of Green Energy Systems Based on Photovoltaic Source for Rural Electrification in Malaysia

**Dr. Mohd Amran Mohd Radzi**

**[amranmr@upm.edu.my](mailto:amranmr@upm.edu.my)**

**Department of Electrical and Electronic Engineering**  
**Universiti Putra Malaysia**  
**Serdang, Malaysia**




**UNIVERSITY  
OF MALAYA**



# Rural Electrification

Households with electricity supply (%)



\* Estimated


Source: Ministry of Rural and Regional Development

There are various existing works on installing renewable systems, potential of evaluating them for further improvement can be carried out, especially with appropriate design.



# Objective

To develop optimal design of fully **green energy systems based on photovoltaic (PV) source** with reasonable cost and appropriate dispatch energy strategy for rural electrification in **two selected areas in Sarawak**





# Studied Areas



# Assessment

## Flowchart



## Configuration of the system

# Kampung Opar - Loads


Electric appliance	Power (W) per hour	Operating hour per day	Average usage (Hour/day)	Usage for 1 unit per day (Wh)	Number of unit	Total usage for 1 house per day (Wh)
Compact fluorescent light bulb	22	18 to 23	5	110	2	220
Refrigerator	120	0 to 24	8	960	1	960
Television	70	18 to 23	5	350	1	350
Fan	50	18 to 23, 13 to 14 (Lunch)	6	300	1	300
Water pump	150	12 to 14	2	300	1	300
TOTAL						2130



From: Fadaeenejad, M., Radzi, M.A.M., AbKadir, M.Z.A., Hizam, H., 2014. "Assessment of hybrid renewable power sources for rural electrification in Malaysia," *Renewable and Sustainable Energy Reviews*, 30, 299–305.

**Ten houses – 21.3 kWh**

# Kampung Opar – Solar Irradiance



Annual average irradiance is 4.62  
kWh/m<sup>2</sup>/day


# Kampung Sungai Merah - Loads

House	Electrical appliance	Power (W) per hour	Average usage (Hour/day)	Usage for 1 unit per day (Wh)	Unit	Total usage for 1 house per day (W/h)
1	Compact fluorescent light bulb 1	26	5	130	1	130
	Compact fluorescent light bulb 2	20	5	100	1	100
	Compact fluorescent light bulb 3	18	5	90	7	630
	CRT television	72	5	360	1	360
	Table fan	48	6	288	2	576
	Ceiling fan	60	6	360	1	360
2	Compact fluorescent light bulb	18	5	90	8	720
	LCD television	50	5	250	1	250
	Table fan	48	6	288	1	288
3	Compact fluorescent light bulb	18	5	90	3	270
	Table fan	48	6	288	1	288
<b>TOTAL</b>						<b>3972</b>

← Surveyed by  
UMPEDAC




# Kampung Sungai Merah – Solar Irradiance



Annual average irradiance is 4.62  
kWh/m<sup>2</sup>/day

# Simulation in HOMER



Optimization variables		
Component	Capacity	
	Kampung Opar	Kampung Sungai Merah
<b>Converter</b>	0 – 5 kW	0 – 5 kW
<b>Battery</b>	0 – 50 kWh	0 – 15 kWh
<b>Photovoltaic</b>	0 – 30 kW	0 – 10 kW
Sensitivity inputs		
Nominal Discount (%)	Diesel Fuel Price (USD)	
3, 6 and 12	0.5, 1, and 2	

# Results in HOMER

HOMER Pro Microgrid Analysis Tool [Kpg Sg Merah.homer] 3.7.6

FILE LOAD COMPONENTS RESOURCES PROJECT SYSTEM HELP

Home Design Results Library Electric #1 Electric #2 Deferrable Thermal #1 Thermal #2 Hydrogen Calculate

**RESULTS**  Tabular  Graphical

Export... Export All... Sensitivity Cases: Left Click on a sensitivity case to see its Optimization Results. Compare Economics... Column Choices...

Sensitivity		Architecture					Cost			System	PV		1kWh LA		
NominalDiscountRate (%)	Diesel Fuel Price (\$/L)	PV (kW)	1kWh LA	Converter (kW)	Dispatch	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Ren Frac (%)	Capital Cost (\$)	Production (kWh)	Autonomy (hr)	Annual Throughput (kWh)	Rectifier Mean Output (kW)
12.00	0.5	2.39	7	0.667	CC	\$0.624	\$6,789	\$268.22	\$4,686	100	2,385	3,210	25	851	0.1
3.00	0.5	2.72	6	0.601	CC	\$0.403	\$9,723	\$288.22	\$4,704	100	2,723	3,665	22	840	0.1
6.0	0.5	2.39	7	0.667	CC	\$0.470	\$8,333	\$285.29	\$4,686	100	2,385	3,210	25	851	0.1
12.00	1	2.39	7	0.667	CC	\$0.624	\$6,789	\$268.22	\$4,686	100	2,385	3,210	25	851	0.1
3.00	1	2.72	6	0.601	CC	\$0.403	\$9,723	\$288.22	\$4,704	100	2,723	3,665	22	840	0.1
6.0	1	2.39	7	0.667	CC	\$0.470	\$8,333	\$285.29	\$4,686	100	2,385	3,210	25	851	0.1

Export... Optimization Cases: Left Double Click on a particular system to see its detailed Simulation Results.  Categorized  Overall

Architecture		Cost			System	PV		1kWh LA		Converter				
PV (kW)	1kWh LA	Converter (kW)	Dispatch	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Ren Frac (%)	Capital Cost (\$)	Production (kWh)	Autonomy (hr)	Annual Throughput (kWh)	Rectifier Mean Output (kW)	Inverter Mean Output (kW)
2.39	7	0.667	CC	\$0.624	\$6,789	\$268.22	\$4,686	100	2,385	3,210	25	851	0.1	0.08

Windows Taskbar: ENG 9:25 PM INTL 1/17/2017



Sensitivity Analysis



Optimization

# Optimal Design

Component/Parameter	Value	
	Kampung Opar	Kampung Sungai Merah
Architecture/PV (kW)	13.3	2.39
Architecture/1kWh LA	36	7
Architecture/Converter (kW)	3.22	0.67
Architecture/Dispatch	Cycle charging	Cycle charging
Cost/Cost of energy (COE) (USD)	0.652	0.624
Cost/Net present cost (NPC) (USD)	<b>38,052</b>	<b>6,789</b>
Cost/Operating cost (USD)	1,660	268.22
Cost/Initial capital (USD)	25,029	4,686
System/Renewable fraction (%)	100	100
PV/Capital Cost (USD)	13,264	2,385
PV/Production (kWh)	17,858	3,210
1kWh LA/Autonomy (hour)	24	25
1kWh LA/Annual Throughput (kWh)	4,526	851
Converter/Rectifier Mean Output (kW)	0.6	0.1
Converter/Inverter Mean Output (kW)	0.4	0.08

# Sensitivity Analysis – Kampung Opar

Sensitivity/Nominal Discount Rate (%)	Sensitivity/Diesel Fuel Price (USD/L)	Architecture/PV (kW)	Architecture/1kWh LA	Architecture/Converter (kW)	Architecture/Dispatch	Cost/COE (USD)	Cost/NPC (USD)	Cost/Operating cost (USD)	Cost/Initial capital (USD)	System/Renewable Fraction (%)	PV/Capital Cost (USD)	PV/Production (kWh)	1kWh LA/Autonomy (hour)	1kWh LA/Annual Throughput (kWh)	Converter/Rectifier Mean Output (kW)	Converter/Inverter Mean Output (kW)
<b>12</b>	0.5	13.3	36	3.22	CC	0.65	38,052	1,660	25,029	100	13,264	17,858	24	4,526	0.6	0.4
<b>3</b>	0.5	13.5	35	3.27	CC	0.43	56,189	1,791	25,005	100	13,523	18,208	24	4,515	0.6	0.4
<b>6</b>	0.5	13.5	35	3.27	CC	0.50	47,608	1,768	25,005	100	13,523	18,208	24	4,515	0.6	0.4
<b>12</b>	1	13.3	36	3.22	CC	0.65	38,052	1,660	25,029	100	13,264	17,858	24	4,526	0.6	0.4
<b>3</b>	1	13.5	35	3.27	CC	0.43	56,189	1,791	25,005	100	13,523	18,208	24	4,515	0.6	0.4
<b>6</b>	1	13.5	35	3.27	CC	0.50	47,608	1,768	25,005	100	13,523	18,208	24	4,515	0.6	0.4
<b>12</b>	2	13.3	36	3.22	CC	0.65	38,052	1,660	25,029	100	13,264	17,858	24	4,526	0.6	0.4
<b>3</b>	2	13.5	35	3.27	CC	0.43	56,189	1,791	25,005	100	13,523	18,208	24	4,515	0.6	0.4
<b>6</b>	2	13.5	35	3.27	CC	0.50	47,608	1,768	25,005	100	13,523	18,208	24	4,515	0.6	0.4

# Sensitivity Analysis – Kampung Sungai Merah

Sensitivity/Nominal Discount Rate (%)	Sensitivity/Diesel Fuel Price (USD/L)	Architecture/PV (kW)	Architecture/1kWh LA	Architecture/Converter (kW)	Architecture/Dispatch	Cost/COE (USD)	Cost/NPC (USD)	Cost/Operating cost (USD)	Cost/Initial capital (USD)	System/Renewable Fraction (%)	PV/Capital Cost (USD)	PV/Production (kWh)	1kWh LA/Autonomy (hour)	1kWh LA/Annual Throughput (kWh)	Converter/Rectifier Mean Output (kW)	Converter/Inverter Mean Output (kW)
<b>12</b>	0.5	2.39	7	0.67	CC	0.624	6,789	268.22	4,686	100	2,385	3,210	25	851	0.1	0.08
<b>3</b>	0.5	2.72	6	0.60	CC	0.403	9,723	288.22	4,704	100	2,723	3,665	22	840	0.1	0.08
<b>6</b>	0.5	2.39	7	0.67	CC	0.470	8,333	285.29	4,686	100	2,385	3,210	25	851	0.1	0.08
<b>12</b>	1	2.39	7	0.67	CC	0.624	6,789	268.22	4,686	100	2,385	3,210	25	851	0.1	0.08
<b>3</b>	1	2.72	6	0.60	CC	0.403	9,723	288.22	4,704	100	2,723	3,665	22	840	0.1	0.08
<b>6</b>	1	2.39	7	0.67	CC	0.470	8,333	285.29	4,686	100	2,385	3,210	25	851	0.1	0.08
<b>12</b>	2	2.39	7	0.67	CC	0.624	6,789	268.22	4,686	100	2,385	3,210	25	851	0.1	0.08
<b>3</b>	2	2.72	6	0.60	CC	0.403	9,723	288.22	4,704	100	2,723	3,665	22	840	0.1	0.08
<b>6</b>	2	2.39	7	0.67	CC	0.470	8,333	285.29	4,686	100	2,385	3,210	25	851	0.1	0.08

# Conclusion & Future Prospect

Japan - ASEAN Science, Technology and Innovation Platform

The work has successfully been carried out to design and simulate the renewable energy systems. The results conclude the optimized results with the lowest NPC.

Appropriate design with comprehensive analysis through powerful software tool like HOMER should provide better future prospect in ensuring **sustainable renewable systems**. The supplied electricity later will provide better life for rural people.

The future work is to consider multi sources for more sustainable renewable systems.





# JASTIP

Japan - ASEAN Science, Technology and Innovation Platform



**UPM**  
UNIVERSITI PUTRA MALAYSIA  
BERILMU BERBAKTI



**UNIVERSITY  
OF MALAYA**

